



2021 Program Redesign Measures - Available 8/15/21

	Name	Standard	Quantity	PG&E Fuel Required	Rebate CZ 1, 4, 11, 12,	Rebate CZ 2, 3, 5	Validation To Claim	Data Collection	Prerequisite	Tech Review	
1	Attic Insulation	"Effective" R-44 or better, installed per CEC QII standards.	100% of accessible attic area (minimum 50% of total attic area)	Gas and/or electric			Photo of ruler next to level of insulation or photo from insulation company stating finished R level.	Upload photo.	None	Verify photo	
			<1800 sq ft Conditioned Area			\$400	\$300				
			>1800 sq ft Conditioned Area			\$600	\$500				
2	Air Sealing	0.35 or better ACHn target, 0.5 ACHn minimum performance, achieved in accordance with BPI standards and ventilated per ASHRAE 62.2. (installation of balanced Heat Recovery Ventilation recommended)	800 square foot conditioned area (at 8 ft average ceiling height) minimum	Gas and/or electric			Photo of manometer indicating home is testing out within 0.35 to 0.5 ACHn. Lower than 0.35 is approved with ventilation added. NOTE: "Test-In" is no longer required.	Photo of manometer.	None	Verify CFM50	
			< 1800 sq ft Conditioned			\$300	\$200				
			> 1800 sq ft Conditioned			\$500	\$300				
3	Duct Sealing	Seal existing ducts to 5% or 10% leakage or less. Total leakage or DLTO accepted to accommodate bi-levels. Add ducting where cavities have been used or seal cavities such as platform returns.	Up to 2 systems (total) per dwelling unit	Gas and/or electric			Total system flow can be determined by either Nominal or Measured approaches. NOTE: "Test In" is no longer required.	Photo of manometer.	None	Verify CFM25	
			10%			\$200	\$200				
			5%			\$300	\$300				



2021 Program Redesign Measures - Available 8/15/21

	Name	Standard	Quantity	PG&E Fuel Required	Rebate CZ 1, 4, 11, 12,	Rebate CZ 2, 3, 5	Validation To Claim	Data Collection	Prerequisite	Tech Review
4	Duct Replacement	Replacement only; R-8 All CZs @ 5% leakage or less.	100% of accessible ducts; up to 2 systems (total) per dwelling unit	Gas and/or electric	\$500	\$500	Duct leakage to the outside or total duct leakage, total system CFM can be nominal or measured.	CF3R	None	Verify CFM25
5	Heat Pump Space Conditioning	15 SEER Cooling or better, 9.0 HSPF or better Heating (14.5 & 8.5 or greater for packaged units or other unique site conditions. Call us for unusual applications.) Must have existing AC.	Up to 2 HVAC systems (total) per dwelling unit	Gas AND electric	\$750	\$750	AHRI Certificate and CF3R	AHRI Certificate and CF3R	Existing heating and cooling , with fuels for both previously supplied by PG&E.	1. Verify old unit SEER. 2. Verify new SEER
HVAC Kickers		Multi-Stage System (anything more than single stage)			\$100	\$100	Model number from CF3R	AHRI Certificate and CF3R	Heat Pump Space Conditioning	Confirm model # from CF3R
		16 SEER or Greater System			\$100	\$100	AHRI or CF3R	AHRI or CF3R	Heat Pump Space Conditioning	Confirm SEER from CF3R
		Manual J Verified	Installed equipment matches Manual J specification within 3,000 Btu rating at equipment.		\$100	\$100	Worksheet	Upload PDF, spreadsheet, or image.	Heat Pump Space Conditioning	Review worksheet
		Manual D Verified	Installed duct work matches Manual D design. .5 total SP or lower.		\$150	\$150	Worksheet	Upload PDF, spreadsheet, or image.	Heat Pump Space Conditioning	Review worksheet



2021 Program Redesign Measures - Available 8/15/21

	Name	Standard	Quantity	PG&E Fuel Required	Rebate CZ 1, 4, 11, 12,	Rebate CZ 2, 3, 5	Validation To Claim	Data Collection	Prerequisite	Tech Review
		Cash for Clunkers	Old unit 10 SEER or lower		\$200	\$200	Picture of old unit name plate if possible, or old unit if name plate is illegible.	Picture of old unit name plate or old unit if name plate is illegible.	Heat Pump Space Conditiong	Confirm SEER of old unit, or use photo.
6	Heat Pump Water Heater	3.24 EF / 3.09 UEF or better	Up to 2 DHWs (total) per dwelling unit	Gas AND electric	\$750	\$750	AHRI Certificate	Upload PDF or image.	None	Confirm unit meets specificatio
7	Whole House Fan	Ducted and/or insulated lid design, ECM motor required, and doors that automatically seal when not in use.	Two per home, subject to sizing conditions.	Electric	\$100	\$100	Photo of installed unit and make and model of fan on SOW.	Input photo and SOW in application.	None	Verify spec via make and model #
8	Smart Thermostat	ENERGY STAR rated or proprietary to manufacturer, DR capable, customer education on use	Up to 2 per dwelling unit	Gas and/or electric	\$50	\$50	Make and model in SOW.	Drop down in application.	Replacing non-smart thermostat.	None
	Multi-Measure Kicker (automatic based on measures selected)	Paid for every additional measure (1-7) on a project. (Excludes kickers and Smart Thermostat)	No limit.		\$100	\$100				Double check to make sure calculation is correct.